

Town of Williamsburg
Application for Residential or Commercial Water Service

Date of Application: _____
Application Fee: \$10

Inspection Fee: \$ 20/visit
Connection Fee: \$500

Total Fee: \$ _____

Payment Received: \$ _____

Name of Owner: _____

Address of owner: _____

Application is hereby made for a permit to connect to the Williamsburg Water System at the property located at: _____

In accordance with the following specifications:

1. The Town Water Department or their designee shall as specified herein and as required approve all work and materials. All brass goods shall be as manufactured by the Red Hed Manufacturing Co., or approved equal.
2. All pipe for Water Services shall be seamless copper water tubing and shall conform to the provisions of ASTM B-88, Type K annealed (soft) AWWA Specification 7S-CR or Federal Specification WWT-799.
3. Corporations shall have a C.C. thread with compression fittings.
4. Unless otherwise approved, only compression end type fittings will be used except where connections to existing services require special fittings.
5. Curb cocks shall open to the LEFT or counter-clockwise. Curb cocks shall have no "waste". Curb Cocks shall have a pre-attached operating rod.
6. Cub boxes shall be non-screw ERIE type, tar coated, cast iron, sliding type arch pattern base with inlaid covers. Covers shall be held in place with bronze bolts and the word "Water" shall be cast into the cover. Curb boxes shaft shall have a minimum inside diameter of 2 ½ inches.
7. The water main shall be designed with a minimum depth to the tope of pipe of five (5) feet.
8. Air release shall be provided at all local high points. Air release device shall consist of either:
 - a) A ¾" corporations, copper tubing, curb stop and box, and a second box for enclosure of the discharge end of the copper tubing OR
 - b) Fire hydrant assembly
9. The Contractor responsible for installation will provide a certificate of insurance to the Town of Williamsburg for liability and automobile before a permit is issued.
10. Commercial installations require a back flow prevention device.
11. Certain residential sections may want to consider a pressure-reducing valve (Bridge St., Dansereau Rd., Edwards ST., Fairfield Ave., Fort Hill Rd., Grove St., Hatfield Rd., High St., Walpole Hill, Kinsley Ave., Maple St., Myrtle Ave., Pine St., Haydenville abutters to RTE 9, and South Main St.
12. Prior to covering the pip, the Contractor will call for an inspection.
13. ONLY a member of the Water Department or their designee will turn on water.

Approved: _____
Water Commissioner

Date: _____

USDA Nondiscrimination Statement
Departmental Regulation 4300-3
Section 7 – November 16, 1999
Recipient Requirements

“In accordance with Federal Law and U.S. Department of Agriculture Policy, this institution is prohibited from discriminating on the basis of race, color, national origin, gender, age or disability. (Not all prohibited bases apply to all programs)

To file a complaint of discrimination, write USDA, Director, Office of Civil Rights, Room 326-W, Whiten Building, 1400 Independence Avenue, SW, Washington, D.C., 20250-9410 or call (202) 720-5964 (voice and TDD).

USDA is an equal opportunity provider and employer.

The following information is requested by the Federal Government in order to monitor our compliance with various civil laws. You are not required to furnish this information, but you are encouraged to do so. The law requires that we may not discriminate based upon this information, nor whether you choose to furnish it. However, if you choose not to furnish it, under Federal regulations we are required to note the race and gender on the basis of visual observation or surname. If you do not wish to furnish the above information, please check the box below.

I do not wish to furnish this information: _____

Race/National Origin:	American Indian or Alaskan Native	_____
	Asian or Pacific Islander	_____
	White, not Hispanic Origin	_____
	Other (please specify)	_____

Gender:	Female	_____
	Male	_____